

**Photo Microscopy Report**

90 Days	Mild Steel	32.92 Mils/Year	
Site Name Main Cooling Tower			
Coupon Installed:	1/20/2007		
Coupon Removed:	4/20/2007		

90 Days	Mild Steel	11.44 Mils/Year	
Site Name Tenant Cooling Tower			
Coupon Installed:	1/20/2007		
Coupon Removed:	4/20/2007		

90 Days	Mild Steel	11.31 Mils/Year	
Site Name Main Chill Loop			
Coupon Installed:	1/20/2007		
Coupon Removed:	4/20/2007		

90 Days	Mild Steel	16.71 Mils/Year	
Site Name Secondary Chill Loop			
Coupon Installed:	1/20/2007		
Coupon Removed:	4/20/2007		